

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20172659, Building Permit - Commercial

Address: 3680 NE AKIN DR, Unit:128, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Khanh Nguyen	Failed	Thursday, December 28, 2017

Corrective Action Required

1	Misc	-FIRE DEPT APPROVAL REQUIRED -WOMAN RESTROOM NOT MEETING THE ACCESSIBILITY REQUIREMENT. WATER CLOSET LOCATED AT DOOR-SIDE WALL WITH NOT ENOUGH WALL SPACE FOR INSTALLING GRAB BARS. PLUMBING UNDER SINK NOT WRAPPED.
---	------	--

Comments: