

---

**PUBLIC WORKS ENGINEERING DIVISION**

## **Inspection Summary**

---

Permit #: PRPWFC20171319, Public Works Infrastructure Permit - Commercial  
LBP V-A

Address: 2900 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
DEI-Site Visit	Steve Robbins	Partial	Wednesday, January 03, 2018

Corrective Action Required

- 1 We found water by the main that still needs to be chlorinated , MODOT has a fireline leak and filled up the hole. I talked with Keith and he is going to pump out the water and cover the line with some more straw.Steve Robbins 01/03/2018 10:27 AM

**Comments:**

---