

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20170916, Building Permit - Commercial

Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mike Copeland	Partial	Wednesday, January 03, 2018
Partial Correction 1 Misc		LINE 6 (2 HOUR WALL) WITNESSED ASSEMBLY OF FIRE INSULATION AND SPRAY BETWEEN AIR GAP IN 2 HOUR WALL. -ROOF TOP FIRESTOP APPROVED	
Partial Correction 2 Misc		SOUTH MECHANICAL ROOM (2 HOUR): NORTH FACE, TOP OUT SCREW PATTERN APPROVED 1ST LAYER (TOP 6 FEET)	
Partial Correction 3 Misc		WEST ELEVATOR SHAFT: ALL APPROVED	
Partial Correction 4 Misc		SOUTH STAIR TOWER, FIRST LAYER SHAFT WALL APPROVED, 2ND LAYER APPROVED, NEED TO INSPECT WHERE FRAMING AROUND LANDING AREA	
Partial Correction 5 Misc		ELEVATOR A, B: SHAFT WALL APPROVED, 1ST LAYER GYP BOARD APPROVED	
<b>In-wall Inspection</b>	Mike Copeland	Partial	Wednesday, January 03, 2018
Partial Correction 1 Misc		-2ND FLOOR EXISTING BUILDING, 2 ROOMS APPROVED TO COVER ADJACENT TO SMOKE BARRIOR	
Partial Correction 2 Misc		3RD FLOOR: ; DATA AND ELECTRIC ROOM APPROVED; WEST WING STAIR APPROVED. APPROVED ALL EXTERIOR WALLS. -NORTH MECHANICAL, EQUIPMENT, EAST STAIR APPROVED	

- SOUTH WING FROM J6 TO LINE 11, MINUS STAIR. REPAIR FIRE PROTECTION FOR STEEL COLUMN AT STAIR
- RM 3-126, 3-128 TO 3-139, 141
- WEST WING:3-101 THRU 3-120, 3-140 THRU 3-154
- APPROVED TO TOP OUT CORRIDORS WEST WING.

WEST WING PATIENT ROOMS APPROVED TO COVER EXCEPT  
WEST TWO ROOMS BATHROOMS

**Comments:**