

# **PUBLIC WORKS ENGINEERING DIVISION**

# **Inspection Summary**

Permit #: PRPWLD20173826, Public Works Land Disturbance Permit

TAILOR MADE LANDING

Address: 1600 SE HAMBLEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item: Inspection:	Inspector:	Outcome:	Date:
DEI-Erosion Sediment Control (ESC) Inspection	Matt Munger	Partial	Thursday, January 04, 2018

# Corrective Action Required

1 Matt Munger 01/02/2018 10:13 AM

The area along the roadway where the original location construction entrance was going to be put in will need silt fence put in. Rick said in an email on 12/21/17 he was going to order the silt fence.

# Corrective Action Required

2 Matt Munger 01/04/2018 9:27 AM

No workers were present. Silt fence from new construction entrance to existing along the roadway has not been installed yet.

#### **Comments:**