

---

**PUBLIC WORKS ENGINEERING DIVISION**

## **Inspection Summary**

---

Permit #: PRPWFC20174064, Public Works Infrastructure Permit - Commercial

COLEMAN EQUIPMENT

Address: 4101 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
DEI-Erosion Sediment Control (ESC) Inspection	John DiMauro	Failed	Thursday, January 04, 2018

Corrective Action Required

1 John DiMauro 01/04/2018 2:47 PM

According to the plans, it appears that some of the Phase 1 ESC devices are missing.

The ESC devices need to be corrected and remain intact for the duration of the project.

**Comments:**

---