

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFR20171746, Public Works Infrastructure Permit - Residential  
Manor at Stoney Creek 2nd - street, storm, sewer and water

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Water Line - Coliform Test 1	Brice Lawson	Passed	Friday, January 05, 2018

Informational

1 Brice Lawson 12/28/2017 1:27 PM  
The day 1 bacterial samples have been taken to Blue Valley Lab.

Informational

2 Brice Lawson 01/05/2018 7:55 AM  
Blue Valley Lab submitted the bacterial test report and all of the samples have passed.

DEI-Water Line - Coliform Test 2	Brice Lawson	Passed	Friday, January 05, 2018
-------------------------------------	--------------	--------	--------------------------------

Informational

1 Brice Lawson 01/02/2018 11:43 AM  
The 2nd set of water samples were collected from the job site and taken to Blue Valley Lab.

Informational

2 Brice Lawson 01/05/2018 7:57 AM  
Blue Valley Lab submitted the bacterial test report and all of the samples passed.

**Comments:**