
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20173845, Public Works Infrastructure Permit - Commercial

Scooters coffee

Address: 805 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer Construction Inspection	Matt Munger	Passed	Friday, January 05, 2018

Informational

- 1 Matt Munger 01/05/2018 9:45 AM
Me and Bob B. checked on the sewer line that was installed. I observed adequate amount of gravel below the pipe and SDR26 was installed. I did observe two cleanouts that they had installed. The Contractor stated he was going to put 8" of gravel above the sewer line.

Comments:
