
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20162861, Building Permit - Residential

Address: 3333 SW JESSIE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sidewalk Inspection	Brice Lawson	Passed	Friday, January 05, 2018

Informational

- 1 Brice Lawson 01/05/2018 12:50 PM
The sidewalk has been installed. The cross slope was spot checked and it was below 2.0%.

Comments:
