

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20180059, Building Permit - Commercial

Address: 1610 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Mike Copeland	Failed	Wednesday, January 10, 2018

Corrective Action Required

1	Misc	-ISOLATED PIERS EAST SIDE POURED WITHOUT INSPECTION -ENCLOSED ADDITION EAST FACING FOOTING, HAVE ENGINEER VERIFY SOIL BEARING CAPACITY AND PROVIDE CLEARANCE TO RE-REINFORCING STEEL
---	------	---

Comments: