

Temporary Certificate of Occupancy

Permit #: PRCOM20172339
Address: 300 SW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64063
Inspected On: Wednesday, January 10, 2018
Inspected By: John Borns
Expiration Date: 1/25/2018 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Wednesday, January 10, 2018

Corrective Action Required:

1	Misc	ROOFTOP INSPECTION TO BE REQUESTED AND PERFORMED WHEN READY.
---	------	--

Corrective Action Required:

2	Misc	PLANNING INSPECTION TO BE REQUESTED AND PERFORMED AFTER FACADE IS COMPLETED AND RTU SCREENING IS IN PLACE.
---	------	--

Corrective Action Required:

5	Misc	AIRLOCK AT SOUTH ENTRANCE SUBJECT TO APPROVAL WHEN INSTALLED (GLAZING MUST BE ETCHED "TEMPERED").
---	------	---