

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20161767, Building Permit - Commercial

Address: 813 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Wednesday, January 10, 2018

Partial Correction

1 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT:

SOUTH STAIRWELL:

1ST FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; 2ND LAYER AT WELL FACE AND PRE-ROCK;

2ND FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; PRE-ROCK ONLY 2ND LAYER; 2ND LAYER WELL FACE;

3RD FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; 2ND LAYER PRE-ROCK ONLY; 2ND LAYER AT WELL FACE AND PRE-ROCK;

4TH FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; 2ND LAYER AT WELL FACE;

TOWER: 1ST & 2ND LAYER AT WELL FACE WALLS +LID; 3RD LAYER + HAT CHANNEL AT LID; 4TH LAYER AT LID; **[1ST LAYER LOWER CEILINGS AT LANDING;**

NORTH STAIRWELL:

1ST FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; 2ND LAYER AT WELL FACE AND PRE-ROCK;

2ND FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; PRE-ROCK ONLY 2ND LAYER; 2ND LAYER WELL FACE;

3RD FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; 2ND LAYER PRE-ROCK ONLY; 2ND LAYER AT WELL FACE AND PRE-ROCK;

4TH FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; 2ND LAYER AT WELL FACE;

TOWER: 1ST & 2ND LAYER AT WELL FACE WALLS +LID; 3RD LAYER + HAT CHANNEL AT LID; 4TH LAYER AT LID; **[1ST LAYER LOWER CEILINGS AT LANDING;**

Partial Correction

2 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT ELEVATOR

Partial Correction

3

Misc

1ST FLOOR: 1ST LAYER PRE-ROCK; 2ND LAYER PRE-ROCK;  
2ND FLOOR: 1ST LAYER PRE-ROCK; PRE-ROCK 2ND LAYER;  
3RD FLOOR: 1ST LAYER PRE-ROCK; 2ND LAYER PRE-ROCK;  
SHAFT FACE: 1ST LAYER AT WALLS + LID; 2ND LAYER AT WALLS +  
LID; **[3RD LAYER + HAT CHANNEL;**

OK TO COVER WHEN READY 5/8" TYPE X:

BEHIND TUBS/SHOWERS ADJACENT TO STAIRWELLS AT:

4TH FLOOR: 1ST LAYER; 2ND LAYER

3RD FLOOR: 1ST LAYER; 2ND LAYER

2ND FLOOR: 1ST LAYER; 2ND LAYER

1ST FLOOR: 1ST LAYER; 2ND LAYER

SHEAR WALLS:

1ST FLOOR: 1ST LAYER @ IT ROOM; 1ST LAYER AT SHEAR WALLS +

2ND LAYER @ IT ROOM; 2ND LAYER AT SHEAR WALLS

**[3RD FLOOR: 1ST LAYER AT SHEAR WALLS AT STAIRWELLS &  
ELEVATOR IN CORRIDOR & UNITS;**

Comments: