

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20173845, Public Works Infrastructure Permit - Commercial

Scooters coffee

Address: 805 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Storm - Material Verification	Matt Munger	Passed	Wednesday, January 10, 2018

Informational

- 1 Matt Munger 01/10/2018 8:30 AM
Looked over the storm pipe that was on site and observed that it was 18" HDPE with bell and spigot ends with AASHTO M294 2306 stamped on the side of the pipe.

I also observed the storm box that was delivered was precast.

Comments: