

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20173801, Public Works Infrastructure Permit - Commercial
Residences at Echelon
Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

| Inspection: | Inspector: | Outcome: | Date: |
|-----------------------------------|-------------|----------|-----------------------------|
| DEI-Storm - Material Verification | Matt Munger | Partial | Wednesday, January 10, 2018 |

Informational

- 1 Matt Munger 01/10/2018 9:00 AM
No work was done on site due to the weather. I looked over the storm sewer pipe and observed: 15", 18" and 24" HDPE pipe with the ASTM F2306 PE, AASHTO M294 stamped on the side. I saw wye fittings that were stamped with Heavy Wall SDR26 in a crate. I also observed 6" CI/PL x 6" CI/PL Flexible Couplings with Strong Rack Ring that was stamped Complies with ASTM:C1173.D5926.

Comments: