

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173241, Building Permit - Residential

Address: 4705 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Khanh Nguyen	Passed	Thursday, January 11, 2018

Comments:

BONDING OF LIGHT NICHE SHELL, PERIMETER DECK, HANDRAIL, AND LADDER-OK