

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20161769, Building Permit - Commercial  
Address: 825 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Wednesday, January 17, 2018

Partial Correction  
1 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT STAIRWELLS:

### EAST STAIRWELL:

1ST FLOOR: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER PRE-ROCK ONLY; 2ND LAYER WALLS ONLY;  
2ND FLOOR: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER PRE-ROCK;  
3RD FLOOR: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER PRE-ROCK; STAIRWELL FACE SIDE WALLS COMMON WITH UNITS 1ST LAYER; **[STAIRWELL FACE SIDE WALLS COMMON WITH UNITS 2ND LAYER;**  
4TH FLOOR: STAIRWELL FACE SIDE WALLS COMMON WITH UNITS 1ST LAYER; **[STAIRWELL FACE SIDE WALLS COMMON WITH UNITS 2ND LAYER;**

### WEST STAIRWELL:

1ST FLOOR: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER PRE-ROCK ONLY; [2ND LAYER WALLS ONLY;  
2ND FLOOR: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER PRE-ROCK;  
3RD FLOOR: 1ST LAYER INCLUDING PRE-ROCK;  
STAIRWELL FACE SIDE WALLS COMMON WITH UNITS 1ST LAYER; **[STAIRWELL FACE SIDE WALLS COMMON WITH UNITS 2ND LAYER;**  
4TH FLOOR: STAIRWELL FACE SIDE WALLS COMMON WITH UNITS 1ST LAYER; **[STAIRWELL FACE SIDE WALLS COMMON WITH UNITS 2ND LAYER;**

Partial Correction

2        Misc

ELEVATOR SHAFT:

1ST FLOOR: 1ST LAYER PRE-ROCK; 2ND LAYER PRE-ROCK

2ND FLOOR: 1ST LAYER PRE-ROCK;

3RD FLOOR: 1ST LAYER PRE-ROCK; 2ND LAYER PREROCK

**Comments:**