

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20162083, Public Works Infrastructure Permit - Commercial

WATER UTILITIES FACILITY

Address: 1200 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Street - Surface Course	Brice Lawson	Failed	Friday, January 19, 2018

Corrective Action Required

1 Brice Lawson 01/19/2018 11:52 AM

The concrete patch that was installed above the storm pipe that crosses Hamblen Rd has settled. The curb on the east side of Hamblen Rd near this patch is broken.

-Submit a plan that shows the proper corrections necessary to fix this settlement.

-Remove and replace the broken curb.

These items will be added to the Punch List.

Comments: