

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20161767, Building Permit - Commercial  
Address: 813 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	John Borns	Passed	Friday, January 19, 2018

<b>Rated Assembly Inspection</b>	John Borns	Partial	Friday, January 19, 2018
--------------------------------------	------------	---------	--------------------------

Partial Correction  
1 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT:  
SOUTH STAIRWELL:  
1ST FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; 2ND LAYER AT WELL FACE AND PRE-ROCK;  
2ND FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; PRE-ROCK ONLY 2ND LAYER; 2ND LAYER WELL FACE;  
3RD FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; 2ND LAYER PRE-ROCK ONLY; 2ND LAYER AT WELL FACE AND PRE-ROCK;  
4TH FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; 2ND LAYER AT WELL FACE;  
TOWER: 1ST & 2ND LAYER AT WELL FACE WALLS +LID; 3RD LAYER + HAT CHANNEL AT LID; 4TH LAYER AT LID; 1ST LAYER LOWER CEILINGS AT LANDING; 2ND LAYER LOWER CEILINGS AT LANDING; 3RD LAYER + HAT CHANNEL @ LOWER CEILINGS AT LANDING; 4TH LAYER @ LOWER CEILINGS AT LANDING

NORTH STAIRWELL:  
1ST FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; 2ND LAYER AT WELL FACE AND PRE-ROCK;  
2ND FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; PRE-ROCK ONLY 2ND LAYER; 2ND LAYER WELL FACE;  
3RD FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; 2ND LAYER

Partial Correction

2 Misc

PRE-ROCK ONLY; 2ND LAYER AT WELL FACE AND PRE-ROCK;  
4TH FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; 2ND LAYER AT WELL FACE;  
TOWER: 1ST & 2ND LAYER AT WELL FACE WALLS +LID; 3RD LAYER + HAT CHANNEL AT LID; 4TH LAYER AT LID; 1ST LAYER LOWER CEILINGS AT LANDING; 2ND LAYER LOWER CEILINGS AT LANDING; 3RD LAYER + HAT CHANNEL @ LOWER CEILINGS AT LANDING; 4TH LAYER @ LOWER CEILINGS AT LANDING

Partial Correction

3 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT ELEVATOR  
1ST FLOOR: 1ST LAYER PRE-ROCK; 2ND LAYER PRE-ROCK;  
2ND FLOOR: 1ST LAYER PRE-ROCK; PRE-ROCK 2ND LAYER;  
3RD FLOOR: 1ST LAYER PRE-ROCK; 2ND LAYER PRE-ROCK;  
SHAFT FACE: 1ST LAYER AT WALLS + LID; 2ND LAYER AT WALLS + LID; 3RD LAYER + HAT CHANNEL AT LID; 4TH LAYER AT LID

OK TO COVER WHEN READY 5/8" TYPE X:  
BEHIND TUBS/SHOWERS ADJACENT TO STAIRWELLS AT:  
4TH FLOOR: 1ST LAYER; 2ND LAYER  
3RD FLOOR: 1ST LAYER; 2ND LAYER  
2ND FLOOR: 1ST LAYER; 2ND LAYER  
1ST FLOOR: 1ST LAYER; 2ND LAYER

SHEAR WALLS:

1ST FLOOR: 1ST LAYER @ IT ROOM; 1ST LAYER AT SHEAR WALLS + 2ND LAYER @ IT ROOM; 2ND LAYER AT SHEAR WALLS  
**2ND FLOOR: [1ST LAYER AT SHEAR WALLS AT STAIRWELLS & ELEVATOR IN CORRIDOR & UNITS;**  
3RD FLOOR: 1ST LAYER AT SHEAR WALLS AT STAIRWELLS & ELEVATOR IN CORRIDOR & UNITS;  
4TH FLOOR: 1ST LAYER AT SHEAR WALLS AT STAIRWELLS & ELEVATOR IN CORRIDOR & UNITS;

Partial Correction

4 Misc

5/8" TYPE X GWB OK TO COVER AT CEILINGS & WALLS AT:  
4TH FLOOR CEILINGS & WALLS COMPLETE INCLUDING 2ND LAYER AT SHEAR WALLS AT STAIRWELLS & ELEVATOR SHAFT ON UNIT/CORRIDOR FACE;

3RD FLOOR CEILINGS & WALLS COMPLETE INCLUDING 2ND LAYER AT SHEAR WALLS;

**Comments: RELEASE ELECTRICAL SERVICE TO ALL METERS AT METER BANK AT NORTH END OF BUILDING.**