

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20172360, Building Permit - Commercial

Address: 300 SW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Monday, January 22, 2018
Partial Correction 1 Misc		OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT: [WEST DEMISING WALL;	
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Monday, January 22, 2018
Partial Correction 1 Misc		OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING EXCEPT CONNECTION TO EXISTING BUILDING DRAIN.	
		NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.	

Comments: