

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20161935, Building Permit - Commercial

Address: 805 NW DONOVAN RD, Unit:G1, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	John Borns	Passed	Monday, January 22, 2018

**Comments: FRAMING AND ELECTRICAL APPROVED AFTER SHEAR WALLS ARE RE-NAILED. OK TO DRYWALL CEILINGS.**