

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161936, Building Permit - Commercial

Address: 805 NW DONOVAN RD, Unit:G2, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Not Ready	Monday, January 22, 2018

Corrective Action Required

1	Misc	SHEAR WALLS TO BE RE-NAILED. ELECTRICAL WIRING NOT INSTALLED.
---	------	---------------------------------------------------------------

Comments: