



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20170618	Date:	January 23, 2018
Project Title:	B&B THEATRES NEW LONGVIEW 7	Applicant:	
Location:		Homeland Security and Electronics	
	3201 SW FASCINATION DR, LEES	1502 N. Metcalf Rd	
	SUMMIT, MO 64081	Louisberg, Ks 66053	
Type of Work:			
Occupancy Group:			
Description:	NEW 7 SCREEN FULL SERVICE MOVIE		
	THEATER WITH FOOD SERVICE		
Construction Type:	Type IIB (Unprotected)		
Map Page:	194F		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:

Acceptance testing of the system will be required prior to the final occupancy inspection. Contact the fire department to schedule testing. (816)969-1300.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.