

Inspection Summary

Permit #: PRCOM20171689, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Partial	Tuesday, January 23, 2018

Comments:
LABEL BREAKER POSTIONS AT PANEL A1-32 LC SEC 2
PHASE 1 BUILDING ADDITION OK FOR USE & OCCUPANCY