

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20173395, Building Permit - Commercial

Address: 3680 NE AKIN DR, Unit:134, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Failed	Thursday, January 25, 2018

### Corrective Action Required

1	Misc	-FIRE DEPT. APPROVAL REQUIRED -FRONT UL SIGNAGE NOT INSTALLED -INSTALL NO SMOKING SIGNAGE AT FRONT -INSTALL RESTROOM SIGNAGE -ABOVE-CEILING MC CABLES CANNOT BE SECURED TO THE CEILING GRID SUPPORT WIRE. INSTALL AN INDEPENDANT SUPPORT WIRE WITH COLOR-ID.
---	------	--

### Comments: