

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20172360, Building Permit - Commercial

Address: 300 SW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Thursday, January 25, 2018
Partial Correction 1 Misc		RATED DEMISING WALL AT WEST: 5/8" TYPE X GWB AT E FACE OK TO TAPE, MUD AND FIRE-STOP;	
In-wall Inspection	John Borns	Partial	Thursday, January 25, 2018
Partial Correction 1 Misc		OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT: WEST DEMISING WALL; [102, 103, 110 N & W WALLS; [INSULATION IN PLACE AT WEST DEMISING WALL WALL CAVITY EXCEPT AT N END OK TO ONE-SIDE AT: HANGING BULKHEAD AT 100; TALL WALLS AT ; [106; 107; 108	

Comments: