

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173141, Building Permit - Residential
Address: 1308 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Partial	Friday, January 26, 2018

Corrective Action Required

1	Misc	GARAGE PORTAL WALL FRAMING-OK
---	------	-------------------------------

Comments: