

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20174120, Building Permit - Commercial

Address: 611 SW 3RD ST, Unit:B, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Friday, January 26, 2018

Corrective Action Required

1	Misc	RESOLVE FIRE DEPARTMENT ISSUES
---	------	--------------------------------

Corrective Action Required

2	Misc	BALCONY GUARD NOT COMPLIANT WITH COMMERCIAL CODE
---	------	--

Corrective Action Required

3	Misc	CURRENT, LEGIBLE, ACCURATE PANEL SCHEDULES REQUIRED AT ELECTRICAL PANELS
---	------	--

Corrective Action Required

4	Misc	ANTI-TIP DEVICE REQUIRED AT BREAK ROOM RANGE
---	------	--

Corrective Action Required

5	Misc	ELECTRICAL RECEPTACLES: - GFCI PROTECTION REQUIRED NEAR BREAK ROOM SINK - APPARENT OPEN GROUND AT MW RECEPT - CHECK ALL ELECTRICAL RECEPTACLES TO ENSURE ALL ARE MOUNTED SOLID TO BOX -- NONE "SOFT" OR LOOSE SIDE-TO-SIDE. USE YOKE SPACERS OR BOX EXTENDERS WHERE NEEDED.
---	------	--

Occupancy Inspection - Fire	Michael Weissenbach	Failed	Friday, January 26, 2018
------------------------------------	---------------------	--------	--------------------------

Comments: