

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20180183, Building Permit - Commercial

Address: 221 NW CHIPMAN RD, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Sewer Service Inspection - Commercial</b>	John Borns	Passed	Monday, January 29, 2018

**Comments: OK TO COVER BUILDING SEWER REPLACED WITH PVC AND HDPE BY PIPE BURST FROM NORTH END OF BUILDING TO CLEANOUT & CONNECTION TO EXSTG CLAY PIPE ~132' NORTH.**