

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFR20171746, Public Works Infrastructure Permit - Residential
Manor at Stoney Creek 2nd - street, storm, sewer and water

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Install Street and Stop Signs	Brice Lawson	Partial	Tuesday, January 30, 2018

Corrective Action Required

- 1 Brice Lawson 01/30/2018 11:46 AM
The street name signs, stop signs and OM4-3 end of the road marker signs have been installed.

It appears that the stop sign installed at Grindstone and Merryman is not going to be 4' to 6' from the proposed sidewalk as shown on the plan details. Relocate sign to proper location.

The OM4-3 markers were removed during construction at the end of SW Lodestone Dr and at future Georgetown Dr on both sides of SW Stoney Creek Dr. Properly install these signs.

Comments: