

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20172360, Building Permit - Commercial

Address: 300 SW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|---|-----------------------------|
| Rated Assembly Inspection | John Borns | Partial | Wednesday, January 31, 2018 |
| Partial Correction 1 Misc | | RATED DEMISING WALL AT WEST: 5/8" TYPE X GWB AT EAST AND WEST FACES OK TO TAPE, MUD AND FIRE-STOP; | |
| In-wall Inspection | John Borns | Partial | Wednesday, January 31, 2018 |
| Partial Correction 1 Misc | | OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT: WEST DEMISING WALL; 102, 103, 110 ALL WALLS; [RESTROOMS COMPLETE; | |
| Underslab Plumbing Inspection - Commercial | John Borns | Partial | Wednesday, January 31, 2018 |
| Partial Correction 1 Misc | | OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING EXCEPT CONNECTION TO EXISTING BUILDING DRAIN. NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM. | |
| Partial Correction 2 Misc | | OK TO COVER WHEN READY WATER LINE ENTRY UNDER FOOTING AT NE CORNER | |

Comments: