Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173195, Building Permit - Residential Address: 4705 NE POCONO CIR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Gas Service Inspection - Khanh Nguyen

Residential

Passed

Wednesday, January 31, 2018

All Rough Inspection - Khanh Nguyen Failed Wednesday, January 31, 2018

Residential

Corrective Action Required

1 Misc F

FRAMING:

- -Close floor opening @ front bed closet
- -Support front of ridge @ front bed
- -Support hips above master bed
- -Security blocking for deck door and basement door
- -Fb wall from furdown space above rear basement bed closet; Fb

basement bath wall from furdown space

MECHANICAL:

- -Min 1" clearance around b vent
- -Lower supply duct to ceiling level at front basement bed
- -Overspanned dryer duct

ELECTRICAL:

- -Complete electrical to entry stoop light
- -Provide wall receptacle spacing peer code in office
- Complete electrical to ceiling lights in office
- -Protect wiring at rear basement bed closet
- -Secure wiring per code @ rear basement bed switch
- -Above front basement bed closet, move the wiring away from touching the dryer duct

^{***}OK TO INSULATE

Electrical Service Khanh Nguyen Passed Wednesday, January 31, 2018 **Inspection - Residential**

Comments: