

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173195, Building Permit - Residential

Address: 4705 NE POCONO CIR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|---|--------------|----------|---------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| All Rough Inspection - Residential | Khanh Nguyen | Failed | Friday, February 02, 2018 |

Corrective Action Required

1 Misc

FRAMING:

-Fb basement bath wall from furdawn space

**I need more insulation to fb the wall at tub and sink

MECHANICAL:

-Overspanned dryer duct

**the duct spans quite a bit with too many elbows. 22-23 ft with five 90 deg elbows

***OK TO INSULATE

Comments: