

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20170922, Building Permit - Residential

Address: 1324 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mike Copeland	Failed	Tuesday, February 06, 2018

Corrective Action Required

1	Misc	-HANDRAILS BASEMENT AND GARAGE ARE REQUIRED TO TERMINATE AT THE NOSING OF THE BOTTOM TREAD. -GARAGE CANTILEVER, INSTALL 5/8THS GYP ON THE UNDERSIDE.
---	------	---

Comments: