

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20173935, Building Permit - Commercial

Address: 910 NW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Commercial</b>	John Borns	Passed	Thursday, February 08, 2018

<b>Miscellaneous Inspection</b>	John Borns	Partial	Thursday, February 08, 2018
---------------------------------	------------	---------	-----------------------------

Partial Correction

1 Misc

ELEMENTS OF LIGHTED SIGN FOUND TO BE UL-LABELED, BUT MANUFACTURER'S LABEL NOT FOUND. WILL ALLOW THIS ONLY TO BE FIELD-LABELED.

**Comments: OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING INCLUDING CONNECTION TO BUILDING DRAIN LINE WHICH IS 3" VS 4" SHOWN ON DRAWINGS. A/E NOTIFIED BUILDING INSPECTOR THAT BUILDING DRAIN SIZE IS ADEQUATE FOR TENANT'S CALCULATED LOADS.**

**NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.**