

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20170916, Building Permit - Commercial

Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mike Copeland	Partial	Thursday, February 08, 2018

Partial Correction

1	Misc	-2ND FLOOR EXISTING BUILDING, 2 ROOMS APPROVED TO COVER ADJACENT TO SMOKE BARRIOR
---	------	---

Partial Correction

2	Misc	3RD FLOOR: ; DATA AND ELECTRIC ROOM APPROVED; WEST WING STAIR APPROVED. APPROVED ALL EXTERIOR WALLS. -NORTH MECHANICAL, EQUIPMENT, EAST STAIR APPROVED -SOUTH WING FROM J6 TO LINE 11, MINUS STAIR. REPAIR FIRE PROTECTION FOR STEEL COLUMN AT STAIR -RM 3-126, 3-128 TO 3-139, 141, 143 -WEST WING:3-101 THRU 3-120, 3-140 THRU 3-154 -APPROVED TO TOP OUT CORRIDORS WEST WING.
---	------	--

WEST WING PATIENT ROOMS APPROVED TO COVER

STAFF LOUNGE APPROVED

Rated Assembly Inspection	Mike Copeland	Partial	Thursday, February 08, 2018
----------------------------------	---------------	---------	-----------------------------

Partial Correction

1	Misc	LINE 6 (2 HOUR WALL) WITNESSED ASSEMBLY OF FIRE INSULATION AND SPRAY BETWEEN AIR GAP IN 2 HOUR WALL. -ROOF TOP FIRESTOP APPROVED
---	------	---

Partial Correction

2	Misc	SOUTH MECHANICAL ROOM (2 HOUR): NORTH FACE, TOP OUT SCREW PATTERN APPROVED 1ST LAYER (TOP 6 FEET)
---	------	---

Partial Correction

3 Misc

WEST ELEVATOR SHAFT: ALL APPROVED, 2nd LAYER FACE
APPROVED

Partial Correction

4 Misc

SOUTH STAIR TOWER, FIRST LAYER SHAFT WALL APPROVED, 2ND
LAYER APPROVED, NEED TO INSPECT WHERE FRAMING AROUND
LANDING AREA

Partial Correction

5 Misc

ELEVATOR A, B: SHAFT WALL APPROVED, 2nd LAYER GYP BOARD
APPROVED

Partial Correction

6 Misc

STAFF ELEVATOR 1: SHAFT WALL APPROVED

Comments: