

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20170916, Building Permit - Commercial

Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Friday, February 09, 2018

Partial Correction

1	Misc	-SOUTH STAIR 3-ST5 APPROVED TO DROP -WEST WING CORRIDOOR ALCOVE HARD LIDS APPROVED. -2 NURSE STATIONS APPROVED -SOILS ROOM APPROVED
---	------	--

[3-160; 161; 163; 165; 166; 167; 185; COR 7;

Rated Assembly Inspection	John Borns	Partial	Friday, February 09, 2018
----------------------------------	------------	---------	---------------------------

Partial Correction

1	Misc	LINE 6 (2 HOUR WALL) WITNESSED ASSEMBLY OF FIRE INSULATION AND SPRAY BETWEEN AIR GAP IN 2 HOUR WALL. -ROOF TOP FIRESTOP APPROVED
---	------	---

Partial Correction

2	Misc	SOUTH MECHANICAL ROOM (2 HOUR): NORTH FACE, TOP OUT SCREW PATTERN APPROVED 1ST LAYER (TOP 6 FEET)
---	------	---

Partial Correction

3	Misc	WEST ELEVATOR SHAFT: ALL APPROVED, 2nd LAYER FACE APPROVED
---	------	--

Partial Correction

4	Misc	SOUTH STAIR TOWER, FIRST LAYER SHAFT WALL APPROVED, 2ND LAYER APPROVED, NEED TO INSPECT WHERE FRAMING AROUND LANDING AREA
---	------	---

Partial Correction

5	Misc	ELEVATOR A, B: SHAFT WALL APPROVED, 2nd LAYER GYP BOARD APPROVED
---	------	--

Partial Correction

6 Misc

Corrective Action Required

7 Misc

STAFF ELEVATOR 1: SHAFT WALL APPROVED

UL-465 GWB FASTENED IN PLACE AT WALLS: **[3-175 S WALL;**

Comments: