

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20173153, Building Permit - Commercial

Address: 805 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Failed	Friday, February 09, 2018

Corrective Action Required

1	Misc	L.P. BASE CAGES ARE #5. DRAWING SAYS SIX #6 REQUIRED.	
---	------	--	--

Underground Electrical Inspection - Commercial	John Borns	Not Ready	Friday, February 09, 2018
---	------------	-----------	---------------------------

Electrical Service Inspection - Commercial	Mark Harding	Passed	Friday, February 09, 2018
---	--------------	--------	---------------------------

Comments: