

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20173638, Building Permit - Commercial

Address: 615 SW 3RD ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Commercial</b>	John Borns	Passed	Monday, February 12, 2018

<b>Occupancy Inspection - Fire</b>	Michael Weissenbach	Passed	Monday, February 12, 2018
--	------------------------	--------	---------------------------

**Comments: MIRROR AT ACCESSIBLE RESTROOM TO BE LOWERED FOR BOTTOM OF GLASS TO BE NO HIGHER THAN 40" A.F.F. CLOSE PERMIT.**