

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20173845, Public Works Infrastructure Permit - Commercial

Scooters coffee

Address: 805 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Commercial Curb Inspection	Matt Munger	Partial	Tuesday, February 13, 2018

Corrective Action Required

- 1 Matt Munger 02/13/2018 11:20 AM
John H. and I spoke with the contractor about making sure to use KCMMB 4k with white cure, smooth #5 dowels instead of what they had put in already. They only had 2 dowels in place, we advised to not use wings for the sidewalk. I had emailed Sheldon our detail for sidewalks, curbs and driveways on 2/12/18. I also called Sheldon and informed him of the concerns I had with what I saw.

Comments: