

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20170104, Building Permit - Residential

Address: 1696 NE PARKWOOD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Wednesday, February 14, 2018

Corrective Action Required

1	Misc	-HAVE THE LAWN IRRIGATION CONTRACTOR TO SUBMIT TO CITY THE BACKFLOW TEST REPORT -KCPL TRANSFORMER IS DISPLACED -PROVIDE MIN SIX INCHES FROM WINDOW SIDING TO GRADE -VERIFY THAT THE DECK POSTS ARE ANCHORED TO THE PIERS -LOOP DISH WASHER DRAIN TO NEAR THE TOP OF CABINET AND SECURE IN PLACE -PEX WATER LINES ABOVE WATER HEATER MUST HAVE MIN. SIX INCHES OF CLEARANCE FROM VENT. INSTALL COPPER TUBINGS FROM WATER HEATER TO CLEAR THE VENT MIN. SIX INCHES, THEN CONNECT THE PEX LINES
---	------	---

Comments: