

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRSITE20180252, Development - Site

TAILOR MADE LANDING

Address: 1600 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Water - Material Verification	Matt Munger	Partial	Wednesday, February 14, 2018

Informational

- 1 Matt Munger 02/14/2018 9:00 AM John D. and I looked over the water materials that were on site. There was approximately 630 Linear Feet of C900 PC 235 on site. The fittings and tees had the fusion bonded epoxy coating on them. 3M Rubberized coating spray for the bolts and there was Class 52 DI pipe on site. All materials were in good condition.

DEI-Water - Material Verification	John DiMauro	Partial	Wednesday, February 14, 2018
-----------------------------------	--------------	---------	------------------------------

Informational

- 1 Matt M. and I looked over the water materials that were on site. There was approximately 630 Linear Feet of C900 PC 235 on site. The fittings and tees had the fusion bonded epoxy coating on them. 3M Rubberized coating spray for the bolts and there was Class 52 DI pipe on site. All materials were in good condition

Comments: