

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20172360, Building Permit - Commercial

Address: 300 SW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:

Inspector:

Outcome:

Date:

**Footing Inspection -
Commercial**

John Borns

Passed

Wednesday, February 14, 2018

Comments: TRENCH FOOTING AT TRUCK DOOR SLAB OK TO POUR WHEN MISSING BARS ARE IN PLACE.