

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20170618, Building Permit - Commercial

Address: 3201 SW FASCINATION DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mark Harding	Partial	Thursday, February 15, 2018

Corrective Action Required

1 Misc

Following areas approved for Ceiling Tile-
theater 1,#2
theater #3,4,5,6,7
lobby,
lounge-102 pending 4 open boxes for strip lights
-107-109;111-114;;111-114;lounge 102, 110, janitor room needs
one can fixed , need to see led boxes when tied in. ok to install
tile.

Comments: