

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173141, Building Permit - Residential
Address: 1308 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|-----------------------------|
| Gas Service Inspection - Residential | Khanh Nguyen | Passed | Thursday, February 15, 2018 |

| | | | |
|--|--------------|--------|-----------------------------|
| Piers/Caissons Inspection - Residential | Khanh Nguyen | Passed | Thursday, February 15, 2018 |
|--|--------------|--------|-----------------------------|

| | | | |
|---|--------------|--------|-----------------------------|
| All Rough Inspection - Residential | Khanh Nguyen | Failed | Thursday, February 15, 2018 |
|---|--------------|--------|-----------------------------|

Corrective Action Required

1 Misc

FRAMING:

- Nail siding per code
- Install collar ties
- Fb fireplace space from roof
- Support vent above master bath
- Fb basement wall per code (vertically every ten ft and from ceiling space)
- Install beam under point loads at foyer

ELECTRICAL:

- Protect wiring within six ft of attic access
- Protect range circuit at master toilet
- Wall receptacle spacing per code rear basement bedroom
- Support and protect wiring per code along I beam in basement

PLUMBING:

- Protect plumbing at kitchen and pantry

***OK TO INSULATE

**Electrical Service
Inspection - Residential**

Khanh Nguyen

Passed

Thursday, February 15, 2018

Comments: