

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20171689, Building Permit - Commercial

Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Commercial</b>	John Borns	Partial	Thursday, February 15, 2018

Partial Correction

1 Misc

OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN,  
WASTE, & VENT PIPING AT: 256 SUBSTERILE; **[PRE-OP AREA  
THREE LOCATIONS;**

NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR  
PRESSURE-TESTING PIPING SYSTEM.

<b>Underslab Electrical Inspection - Commercial</b>	John Borns	Partial	Thursday, February 15, 2018
---	------------	---------	-----------------------------

Partial Correction

1 Misc

NO ISSUES FOUND ON UNDER-SLAB ELECTRICAL CONDUIT  
MATERIAL & WORKMANSHIP AT: **[PRE-OP AREA ONE LOCATION;**

Comments: