

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20172129, Building Permit - Commercial

Address: 834 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Partial	Thursday, February 15, 2018

Partial Correction

1	Misc	PRESSURE TEST ON COMPLETE SYSTEM HELD STEADY AT >10 PSI FOR >10 MIN.
---	------	--

Corrective Action Required

2	Misc	IFGC 404.8: METALLIC PIPING EXPOSED TO WEATHER MUST BE PERMANENTLY PROTECTED WITH PAINT OR BY OTHER APPROVED MEANS. SEE NEW GAS PIPING AT ROOFTOP.
---	------	--

Comments: