

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20161769, Building Permit - Commercial

Address: 825 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Thursday, February 15, 2018

Partial Correction

1 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT STAIRWELLS:

### EAST STAIRWELL:

1ST FLOOR: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER PRE-ROCK ONLY; 2ND LAYER WALLS ONLY;

2ND FLOOR: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER PRE-ROCK;

3RD FLOOR: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER PRE-ROCK; STAIRWELL FACE SIDE WALLS COMMON WITH UNITS 1ST LAYER; STAIRWELL FACE SIDE WALLS COMMON WITH UNITS 2ND LAYER;

4TH FLOOR: STAIRWELL FACE SIDE WALLS COMMON WITH UNITS 1ST LAYER; STAIRWELL FACE SIDE WALLS COMMON WITH UNITS 2ND LAYER;

TOWER ABOVE 4TH FLOOR: 1ST LAYER AT CEILING & WALLS; 2ND LAYER AT CEILING & WALLS; 4TH LAYER AT HIGH CEILING; 2ND LAYER AT LOWER CEILINGS; 2ND LAYER AT WALLS; 3RD LAYER + HAT CHANNEL @ LOWER CEILINGS; 4TH LAYER @ LOWER CEILINGS;

### WEST STAIRWELL:

1ST FLOOR: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER PRE-ROCK ONLY; 2ND LAYER WALLS ONLY;

2ND FLOOR: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER PRE-ROCK;

3RD FLOOR: 1ST LAYER INCLUDING PRE-ROCK; STAIRWELL FACE SIDE WALLS COMMON WITH UNITS 1ST LAYER; STAIRWELL FACE SIDE WALLS COMMON WITH UNITS 2ND LAYER;

Partial Correction

2 Misc

4TH FLOOR: STAIRWELL FACE SIDE WALLS COMMON WITH UNITS  
1ST LAYER; STAIRWELL FACE SIDE WALLS COMMON WITH UNITS  
2ND LAYER;

TOWER ABOVE 4TH FLOOR: 1ST LAYER AT CEILING & WALLS; 2ND  
LAYER AT CEILING & WALLS; 4TH LAYER AT HIGH CEILING; 2ND  
LAYER AT LOWER CEILINGS; 2ND LAYER AT WALLS; 3RD LAYER +  
HAT CHANNEL @ LOWER CEILINGS; 4TH LAYER @ LOWER  
CEILINGS;

ELEVATOR SHAFT:

1ST FLOOR: 1ST LAYER PRE-ROCK; 2ND LAYER PRE-ROCK

2ND FLOOR: 1ST LAYER PRE-ROCK;

3RD FLOOR: 1ST LAYER PRE-ROCK; 2ND LAYER PRE-ROCK

SHAFT INNER FACE: 1ST LAYER FULL HEIGHT; **[2ND LAYER FULL  
HEIGHT;**

SHAFT CEILING: 1ST LAYER; 2ND LAYER;

Partial Correction

3 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB:

4TH FLOOR: BEHIND TUBS/SHOWERS 1ST LAYER, 2ND LAYER;  
LOCATIONS FOR SOFFITS & DROP CEILINGS; CEILINGS AND WALLS  
THROUGHOUT, INCLUDING 2ND LAYER AT STAIRWELLS &  
ELEVATOR SHAFT;

3RD FLOOR: BEHIND TUBS/SHOWERS 1ST LAYER, 2ND LAYER;  
**[1ST LAYER AT BACKSIDE OF STAIRWELLS & ELEVATOR SHAFT IN  
CORRIDR & UNITS;**

2ND FLOOR: BEHIND TUBS/SHOWERS 1ST LAYER, 2ND LAYER;

1ST FLOOR: BEHIND TUBS/SHOWERS 1ST LAYER, 2ND LAYER;

**Comments:**