

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20173935, Building Permit - Commercial

Address: 910 NW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Friday, February 16, 2018
Partial Correction 1 Misc		OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS EXCEPT WHERE HAT CHANNEL HAS YET TO BE INSTALLED PRIOR TO APPLICATION OF GWB	
Rough Electrical Inspection - Commercial	John Borns	Partial	Friday, February 16, 2018
Partial Correction 1 Misc		NO ISSUES FOUND ON RECONFIGURATION OF ELECTRICAL SERVICE	

Comments: