

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20170916, Building Permit - Commercial

Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mike Copeland	Partial	Tuesday, February 20, 2018

Partial Correction

1 Misc

LINE 6 (2 HOUR WALL) WITNESSED ASSEMBLY OF FIRE INSULATION AND SPRAY BETWEEN AIR GAP IN 2 HOUR WALL.
-ROOF TOP FIRESTOP APPROVED

Partial Correction

2 Misc

SOUTH MECHANICAL ROOM (2 HOUR): NORTH FACE, TOP OUT SCREW PATTERN APPROVED 1ST LAYER (TOP 6 FEET)

Partial Correction

3 Misc

WEST ELEVATOR SHAFT: ALL APPROVED, 2nd LAYER FACE APPROVED

Partial Correction

4 Misc

SOUTH STAIR TOWER, FIRST LAYER SHAFT WALL APPROVED, 2ND LAYER APPROVED, NEED TO INSPECT WHERE FRAMING AROUND LANDING AREA

Partial Correction

5 Misc

ELEVATOR A, B: SHAFT WALL APPROVED, 2nd LAYER GYP BOARD APPROVED

Partial Correction

6 Misc

STAFF ELEVATOR 1: SHAFT WALL APPROVED; FIRST LAYER APPROVED; SECOND LAYER APPROVED

Partial Correction

7 Misc

UL-465 GWB FASTENED IN PLACE AT WALLS: [3-175 S WALL and N WALL

Partial Correction

8

3-ST6 (WEST STAIR TOWER) 1" SHAFT APPROVED

Comments: