Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173141, Building Permit - Residential Address: 1308 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Khanh Nguyen Failed Tuesday, February 20, 2018

Residential

Corrective Action Required

1 Misc FRAMING:

-Fb basement wall per code (vertically every ten ft and from

ceiling space)

ELECTRICAL:

-Support and protect wiring per code along I beam in basement

**support the NM cables at least every 4.5 ft. Look above and

near the furnace. Check this at final

***OK TO INSULATE

Comments: