

---

**PUBLIC WORKS ENGINEERING DIVISION**

## **Inspection Summary**

---

Permit #: PRPWFC20173845, Public Works Infrastructure Permit - Commercial

Scooters coffee

Address: 805 SW M 150 HWY, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
DEI-Erosion Sediment Control (ESC) Inspection	Matt Munger	Failed	Tuesday, February 20, 2018

Corrective Action Required

1 Matt Munger 02/20/2018 11:20 AM

The silt fence is down on the SW corner of the site. ESC is not in compliance will need to be in place at the end of day on 2/21/18 or a Stop Work Order can be issued.

**Comments:**

---